




The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner

November 16, 2005

**LETTER OF CLOSURE FOR
LETTER OF DEFICIENCY #WSEB 03-048**

Michael Pillsbury
NH Department of Transportation
Bureau of Highway Maintenance
PO Box 483
Concord, NH 03302-0483

Subject: Springfield – Public Water System: Springfield Rest Area (EPA #2179010)

Dear Mr. Pillsbury:

Based on a recent review of the file for Springfield Rest Area, the Department of Environmental Services (DES) has determined that the **Nitrate** levels have been below the maximum contaminant level of **10.0 mg/L** for over a year. Therefore, DES hereby closes Letter of Deficiency #WSEB 03-048, dated July 3, 2003 (the "LOD"). As such, the actions requested in the LOD are not enforceable at this time. Please note, this letter does not release the system from other pending enforcement actions that are still in effect and enforceable.

Please continue to submit water samples according to your Master Sampling Schedule.

If you have any questions, please contact me by phone at (603) 271-0655, or by e-mail at agourley@des.state.nh.us.

Sincerely,

Allyson Gourley
Monitoring & Enforcement Section
Water Supply Engineering Bureau

h:\wsebenfmon\enforce\lods\chem mon\2005\2005 letters of closure\2179010 loc for lod 03-048.doc

cc: Gretchen R. Hamel, DES Legal Unit Administrator ✓
Thomas H. Duling, Springfield Health Officer
Philip Huntley, Sampling Agent
EPA, Region 1
File